



PRODUCT TEST REPORT

Description		Armour rod		specification	IAR9327 for conductor 266.8MCM
Standar		-		Quantity	-
No.	Properties	Standard requirements	Unit	Test results	Determine
1	Manufacturer	LAURENCE		LAURENCE	P
2	Number of wires	12		12	P
3	Material	Alunimium		AL5056	P
4	Dia. of single steel wire	4.61	mm	4.61	P
5	Length	1930	mm	1930	P
6	Lay Direction	right		right	P
Results		Comply standard and allow shipment.			

LInspection / Date: Xu Manjian

Approval / Date: Li Guangen

杭州益睿电线电缆有限公司
HANGZHOU EASY ELECTRIC WIRE AND CABLE CO., LTD.