



## TEST REPORT

Products code	SO2306-0064-2	Test standard	IEC60092-353		
Type specification	CJPF/SC 3*2.5	Date of inspection	2023.6.18		
NO.	Test Items	Unit	Standard Requirements	Actual result	Conclusion
1	(+20℃) D.C resistance of conductor	Ω/Km	Max 8.21	8.16 8.16 8.16	Qualified
2	voltage test(3.5kV/5min)	/	No breakdown	Pass Pass Pass	Qualified
3	(+20℃) Ki Insulation resistance constant	MΩ*Km	Min 3670	5661 5530 5529	Qualified
4	Cable marking	/	The marking should be durable,legible.	Coincidence	Qualified
5	Lengths	m	/	200	/
Conclusion	The above mentioned products has been inspected and found to be in compliance with the stipulation of standard.				

Inspector: XIAOHONG XU

Approval: ZHIQIANG WANG

杭州益睿电线电缆有限公司  
HANGZHOU EASY ELECTRIC WIRE AND CABLE CO., LTD.