



Hangzhou Easy Electric Wire and Cable Co.,LTD

Add: Room 305, Building 2, No. 380 Fengxin Road, Hangzhou, China

www.eescable.com

# TEST REPORT

Product name: Galvanized steel strand Report No: PUO.20230926004

Model Specifications: 7\*2.65mm Inspection date: 2023.10.9

Length: 40000m Test based on: ASTM A475

NO	Test items	unitunit	standard requirement	test result
1	structure size			
1.1	Number of conductor single wires	root	Steel Strand7/2.65	Steel Strand7/2.65
1.2	single line tensile strength	N/mm2	1300Mpa	1429Mpa
1.3	Strand outer diameter	mm	7.95	7.95
1.4	Twist		left	left
1.5	pitch ratio	times	10-16	14.5
2	twine	circle	8	8
2.1	Winding core diameter	times	4	4
5	Thermal extension test	KN	49.79	54.75
5.1	elongation under load	%	≥4	4.4
5.2	Zinc layer weight	g/m <sup>2</sup>	≥244	265
6	printed logo		hot print, complete, clear	accord
7.1	Cabling direction	mm	left	left

Conclusion: The inspected items meet the requirements of technical agreement standards.

Inspection: Sun Lina

Review: Qiao Yinna

Approval: Li Xiaosan

杭州益睿电线电缆有限公司  
HANGZHOU EASY ELECTRIC WIRE AND CABLE CO., LTD.