



Hangzhou Easy Electric Wire and Cable Co.,LTD

Add: Room 305, Building 2, No. 380 Fengxin Road, Hangzhou, China

www.eescable.com

TEST REPORT

Product name: Galvanized steel strand Report No: PUO.20230321001

Model Specifications: 7*2.65mm Inspection date: 2023.04.19

Length: 2000m Test based on: ASTM A475

NO	Test items	unitunit	standard requirement	test result
1	结构尺寸			
1.1	Number of conductor single wires	root	Steel Strand7/2.65	Steel Strand7/2.65
1.2	single line tensile strength	N/mm2	1290Mpa	1428Mpa
1.3	Strand outer diameter	mm	7.95	7.97
1.4	Twist		left	left
1.5	pitch ratio	times	10-16	14.2
2	twine	circle	8	8
2.1	Winding core diameter	times	4	4
5	Thermal extension test			
5.1	elongation under load	%	≥4	4.2
5.2	Zinc layer weight	g/m ²	≥244	262
6	printed logo		hot print, complete, clear	accord
7.1	Cabling direction	mm	left	left

Conclusion: The inspected items meet the requirements of technical agreement standards.

Inspection: Sun Lina
Xiaosan

Review: Qiao Yinna

Approval: Li

杭州益睿电线电缆有限公司
HANGZHOU EASY ELECTRIC WIRE AND CABLE CO., LTD.