



Hangzhou Easy Electric Wire and Cable Co.,LTD

Add: Room 305, Building 2, No. 380 Fengxin Road, Hangzhou, China

www.eescable.com

TEST REPORT

Product name: Galvanized steel strand Report No: PUO.20230926004

Model Specifications: 7*1.57mm Inspection date: 2023.10.9

Length: 10000m Test based on: ASTM A475

NO	Test items	unitunit	standard requirement	test result
1	structure size			
1.1	Number of conductor single wires	root	Steel Strand7/1.57	Steel Strand7/1.57
1.2	single line tensile strength	N/mm2	1310Mpa	1524Mpa
1.3	Strand outer diameter	mm	4.71	4.73
1.4	Twist		left	left
1.5	pitch ratio	times	10-16	14
2	twine	circle	8	8
2.1	Winding core diameter	times	4	4
5	Thermal extension test	KN	17.74	20.65
5.1	elongation under load	%	≥4	4.2
5.2	Zinc layer weight	g/m ²	≥153	196
6	printed logo		hot print, complete, clear	accord
7.1	Cabling direction	mm	left	left

Conclusion: The inspected items meet the requirements of technical agreement standards.

Inspection: Sun Lina

Review: Qiao Yinna

Approval: Li Xiaosan

杭州益睿电线电缆有限公司
HANGZHOU EASY ELECTRIC WIRE AND CABLE CO., LTD.