



TEST REPORT

Products code	SO2306-0064-1	Test standard	IEC60092-353		
Type specification	CJPF/SC 3*1.5	Date of inspection	2023.6.18		
NO.	Test Items	Unite	Standard Requirements	Actual result	Conclusio n
1	(+20°C) D.C resistance of conductor	Ω/Km	Max 13.7	13.3 13.5 13.5	Qualifaied
2	voltage test(3.5kV/5min)	/	No breakdown	Pass Pass Pass	Qualifaied
3	(+20°C) Ki Insulation resistance constant	MΩ*Km	Min 3670	5661 5638 5629	Qualifaied
4	Cable marking	/	The marking should be durable,legible.	Coincidence	Qualifaied
5	Lengths	m	/	200	/
Conclusion	The above mentioned products has been inspected and found to be in compliance with the stipulation of standard.				

Inspector: XIAOHONG XU

Approval: ZHIQIANG WANG

杭州益睿电线电缆有限公司
HANGZHOU EASY ELECTRIC WIRE AND CABLE CO., LTD.